



Case. No. 402382 **Case Entered Date:** 05/15/2014 **Case Status:** Open
Address: 111 E. CHESTNUT ST
Case. Type: CONSERVATION COMPLAINT INVSTC
Description: BUILDING VIOLATIONAutocreated from CSR# 140694389 via mobility on 5/23/2014

Inspections

Insp. #	Insp. Type	Partial	Waived	Started	Completed	Insp. By	Status	Modified By
11254116	CN_COMPL	N	N	05/15/2014	05/15/2014	365764	FAILED	365764

Comments:

Autocreated from CSR# 140694389 via mobility on 5/23/2014 4:24:46 PM

NC2011 - Performed or allowed work to be performed without submitting plans prepared, signed and sealed by a licensed architect or registered structural engineer for approval and without obtaining a permit to perform the work. (13-32-010, 13-32-040, 13-40-020, 13-12-050) 50th floor Unit A and K; 51st floor Unit A - Unit doors moved into common corridor, thus increasing the unit interior exit travel distance to the fire rated corridor. Submit plans to verify life safety requirements and obtain a building permit.

OPEN